



DECLARATION OF PERFORMANCE

No SNF_DOP_006

1. Unique identification code of the product-type:

Dow Corning® FIRESTOP 700

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

Effective from 1st November 2013

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Fire stopping sealant for fire stopping of linear gap seals

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

**Dow Corning Europe S.A.
 1 rue Jules Bordet, parc industriel zone C
 7180 Seneffe, Belgium**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1+

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

N/A

(name and identification number of the notified body, if relevant) performed under system
 (description of the third party tasks as set out in Annex V) and issued

(certificate of constancy of performance, certificate of conformity of the factory production control, test/calculation reports – as relevant)

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Ubatc

(name and identification number of the Technical Assessment Body, if relevant) issued :



BCCA 0749

(reference number of the European Technical Assessment)
on the basis of

ETA 13/0281

(reference number of the European Assessment Document) performed **N/A** under system

(description of the third party tasks as set out in Annex V)
and issued

(certificate of constancy of performance, certificate of conformity of the factory production control,
test/calculation
reports – as relevant)

9. Declared performance

Reaction to Fire classification report No. RA11-0067
According to the Europeans Standard NF EN 13501-1

✓ Classification: B - s2, d0

According ETAG N° 026 part 3 for Linear Joint and Gap Seal

Use category Z2

Durability

Dow Corning Firestop 700 has been tested in accordance with EOTA Technical Report, TR 024 – Edition November 2006, Table 4.1 for the Z2(+5/+40) use category as specified in ETAG 026: Part 3.

Curing behavior

- Curing rate (at 23°C and 50% relative humidity): approximately 2 mm / day;
- Skin-forming time (at 23°C and 50% relative humidity): approximately 90 min;
- Volume shrinkage: less than 5%.

Other

Classification EN ISO 11600: 25LM F& G according SNJF Certification

Where pursuant to Article 37 or 38 the Specific Technical Documentation has been used, the requirements with which the product complies:

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.



This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Gregory Chambard

(name)

Science & technology Manager

(Function)

The information contained herein is provided in good faith and deemed accurate at the date of publication of this document. Notwithstanding any intended uses specified in this document, due to differing conditions of use, the user remains liable to ensure the Product is suitable for its intended uses and applications and is legally compliant for the same. Therefore, Dow Corning makes not warranty express or implied regarding the fitness of the Product for any particular purpose. This information should not be construed as legal advice. Sales of the Product remain subject to the applicable terms and conditions of sale. User should refer to the Product Safety Data Sheet any user guidance provided in connection with the use of the Product.